

Ref br.: BO 500 3552

Beograd, 26/08/2022.

SERTIFIKAT O KONTROLISANJU BR. / CERTIFICATE No: 220332-7	
Klijent/ <i>Client:</i>	„IZO-EKOMONT“ d.o.o. Nemanjina br.232, 11500 Obrenovac
Obim i vrsta kontrolisanja/ <i>Type and scope of inspection:</i>	Kvalitativno kontrolisanje sistema za detekciju curenja, saglasno standardu SRPS EN 14419:2020/EN 14419:2019/ <i>Qualitative inspections of surveillance system according to standard SRPS EN 14419:2020/EN 14419:2019</i>
Predmet kontrolisanja/ <i>Subject of inspection:</i>	Cevovodi za daljinsko grejanje. Predizolovani sistemi cevi direktno spojenih na podzemnu toplovodnu mrežu – sistem za nadzor/ <i>Districts heating pipes. Bonded single and twin pipe systems for buried hot water networks – Surveillance systems</i> Predizolovani elementi/ <i>Preinsulated elements:</i> - Cevi/ <i>pipes</i> - Fitinzi/ <i>fittings</i> - Ventili/ <i>valves</i> - Spojnice/ <i>joints</i>
Proizvođač/ <i>Manufacturer:</i>	„IZO-EKOMONT“ d.o.o. Nemanjina br.232, 11500 Obrenovac
Mesto i datum kontrolisanja/ <i>Place and date of inspection:</i>	Pogon firme/ <i>Production plant:</i> „IZO-EKOMONT“, 01.04.2022.- 25.08.2022.

Ovim potvrđujemo da smo na osnovu usvojene ponude br. 55_2131.19 IND2 izvršili/ *We hereby confirm that, based on offer No 50_2131.19 IND2 following activities were performed:*

- pregled dokumentacije/*Documentation review*
- praćenje postupka montaže i proizvođačke kontrole kvaliteta/*Inspection of installing processes and manufacturer quality control*
- uzorkovanje i ispitivanje za potrebe kontrolisanja/*Sampling and testing for quality control*

Nakon realizacije predmetnog kontrolisanja, a na osnovu izveštaja broj 50-2 0184/22, 50-2 0185/22, 50-2 0186/22 i 50-2 0187/22 utvrđeno je sledeće/*Based on inspection results, and reports No: 50-2 0184/22, 50-2 0185/22, 50-2 0186/22 i 50-2 0187/22 it is noted:*

- Sistem za dojavu instaliran u skladu sa pisanim uputstvom i planom kontrole/*Surveillance system installed according to installing instruction and inspection testing plan*
- Kontrolisanjem neprekidnosti sistema i električnog otpora konstatovana usaglašenost sa zahtevima standarda SRPS EN 14419/*Inspection of continuity and electrical resistance determined compliance with standard SRPS EN 14419*

Izjava o usaglašenosti/Declaration of conformity:

Sistem za dojavu curenja i dokumentacija proizvođača „IZO-EKOMONT“ d.o.o, usaglašeni su sa zahtevima standarda/*Surveillance system and documentation of manufacturer „IZO-EKOMONT“ d.o.o are in accordance with requirements of standards: SRPS EN 14419:2020/EN 14419:2019, SRPS EN 13941-1:2019/EN 13941-1:2019, SRPS EN 13941-2:2019/EN 13941:2019*

Managing Director:
Marinko Ukropina

This document is issued by the Company under its General Conditions of Service accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>. The Client's attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any other holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Beograd Ltd | Jurija Gagarina 7b 11000 Beograd Serbia t (381-11) 71 55 275 t (381-11) 71 55 276 t (381-11) 71 55 277
sgs.beograd@sgs.com www.sgs.com t (381-11) 71 55 278 f (381-11) 22 84 841 f (381-11) 71 55 279

Member of the SGS Group (Société Générale de Surveillance)